



NOTE: NO EQUIPMENT SHALL REACH WITHIN 15' OF OVERHEAD POWER LINES.

NOTE: 3 DAYS NOTICE TO NI-MO, BEFORE START OF WORK. NO PARKING OF TRUCKS, CARS, OR EQUIPMENT ON R.O.W.

KEY PLAN

NOTES

UNAUTHORIZED ALTERATIONS OR ADDITIONS TO THIS DOCUMENT IS A VIOLATION OF SECTION 7209 SUBDIVISION 2 OF THE NEW YORK STATE EDUCATION LAW

REVISIONS			
DATE	BY	DESCRIPTION	SYMBOL
8/81	E.O.	PUMP STA. & SEWERS RELOCATED.	
11/88	E.O.	R.P.	

J. KENNETH FRASER AND ASSOCIATES, P.C.

CONSULTING ENGINEERS
RENSELAER, NEW YORK

BETHLEHEM SEWER DISTRICT

TOWN OF BETHLEHEM
ALBANY COUNTY NEW YORK

USEPA-NYSDEC PROJECT C-36-1096

CONTRACT NO. 2
COLLECTING SEWERS

SCALE: HORIZONTAL 1" = 50'
VERTICAL 1" = 10'

PROJ. ENG'R.: W.T.B.
DRAWN BY: G.L.M.
TRACED BY: G.L.M.
CHECKED BY: W.T.B.
REF. No. 5118

SHEET TITLE: LAURALANA HEIGHTS
PUMP STA. & FORCE MAIN

DATE: JUNE 1981 SHEET 27 OF 32

SOIL BORING LOGS - MAY 1981

Probe #	Description	Ground Water
P-208	Brown silt & clay 0'-8' Gray clay 8'-30'	None
P-209	Brown silt & clay 0'-5' Gray clay 5'-30'	None
P-210	Gravel fill 0'-2' Brown silt & clay 2'-7'	None

RECORD PLAN

