


ELECTRICAL PLAN/FOUNDATION FLOOR

SCALE: 3/8"=1'-0"

ELECTRICAL LEGEND	
SYMBOLS	DESCRIPTION
	PANEL - 1 PHASE, 120/240V, 200 AMP-
	FLUORESCENT FIXTURE
	INCAND. EXTERIOR LIGHT
	EXIT LIGHT
	EMERGENCY LIGHT
	UNIT HEATER
	INCANDESCENT
	SWITCH

PANEL - 1 PHASE, 120/240V, 200 AMP-




EXISTING PRV STATION
NORTH SIDE NYS RT. 85

CONDUITS (BORE UNDER ROAD) BY E.C.
1 ELECTRICAL
1 CONTROL
1" DIA. COATED RIGID GALV. STEEL
WATER TIGHT

MARINE PLYWOOD
4' X 4' X 3/4"
PANEL P1

UNDERGROUND SERVICE

NIMO POLE #176
SHEET 12



POLE MOUNT-BLACK GALV.
STEEL 4' DEEP X 2'SQ. CONC.
FOUNDATION BY E.C.

ELECTRICAL PLAN/GRADE FLOOR

SCALE: 3/8"=1'-0"

SCHEDULE				
ITEM	ITEM	DESCRIPTION	REMARKS	MANUFACTURE
	FLUORESCENT FIXTURE	2-40W LAMPS. 4' LG	DAMP RESISTANT COLD WEATHER BALLAST	KEystone NAUTILUS LU-240-DMR
	INCAND. EXTERIOR LIGHT	100W COLONIAL	W/ PHOTOCNTROL POLYCARB SHIELD	KEEN OLA15-300
	EXIT LIGHT	AC/DC	CONNECT W/ EMERGENCY LITE	EMERGI-LITE X SERIES
	EMERGENCY LIGHT	NICKEL-CADMIUM BATTERY		EMERGI-LITE JSC 25-2
	UNIT HEATER	5KW ELECTRIC SUSP. FROM CEILING	W/THERMOSTAT (40°-70°) AND FAN	
	INCANDESCENT	100W VAPOR PROOF		STONCO VCXC-116C

J. KENNETH FRASER
AND ASSOCIATES, P.C.
CONSULTING ENGINEERS
RENSSELAER, NEW YORK



TOWN OF BETHLEHEM
ALBANY COUNTY NEW YORK

PUMP STATION AND
PRESSURE REDUCING
VALVE STATION

CONTRACT NO. 3G
GENERAL CONSTRUCTION

AND/OR

CONTRACT NO. 3E
ELECTRICAL WORK



PRV STATION
HVAC & ELECTRICAL PLAN