

GENERAL CONSTRUCTION NOTES

- SIZE AND LOCATION OF UNDERGROUND UTILITIES ARE SUBJECT TO VERIFICATION BY THE CONTRACTOR BEFORE CONSTRUCTION BEGINS.
- PRIOR TO START OF CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE U.F.P.O. INC. (1-800-962-7962 OR 811) FOR VERIFICATION OF THE LOCATION OF UNDERGROUND UTILITIES AT LEAST 48 HOURS PRIOR TO THE START OF EXCAVATION.
- THE PLANS SHOW KNOWN SUBSURFACE STRUCTURES, ABOVE GROUND STRUCTURES AND/OR UTILITIES BELIEVED TO EXIST IN THE WORK AREA. THE EXACT LOCATION MAY VARY FROM THE LOCATIONS INDICATED. UNDERGROUND UTILITIES ARE SHOWN FROM FIELD LOCATIONS IF POSSIBLE. OTHERS ARE SHOWN FROM RECORD DATA. THEIR EXACT LOCATIONS MAY DIFFER FROM THAT AS SHOWN, AND OTHERS MAY EXIST. CONTRACTOR SHALL BE RESPONSIBLE TO CONDUCT EXPLORATORY TEST PITS AS MAY BE REQUIRED TO DETERMINE UNDERGROUND CONDITIONS, THE COST OF WHICH SHALL BE INCLUDED IN THE VARIOUS ITEMS IN THIS CONTRACT.
- THE CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO PROTECT AND PRESERVE EXISTING UTILITIES.
- ALL UTILITIES DAMAGED OR DISTURBED BY THE WORK OF THIS CONTRACT SHALL BE REPLACED IN KIND BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE OWNER AND/OR THE TOWN OF BETHLEHEM.
- CONTRACTOR SHALL OBTAIN THE REQUIRED PERMITS FOR WORK WITHIN PUBLIC RIGHT OF WAY AS REQUIRED BY THE TOWN AND THE NYSDOT AND ALL PERMITS REQUIRED FOR UTILITY WORK ON-SITE FROM THE TOWN.
- ALL PERMITS REQUIRED FOR WORK ON-SITE SHALL BE OBTAINED PRIOR TO COMMENCEMENT OF CONSTRUCTION.
- THERE SHALL BE NO CHANGES ON THESE PLANS IN ADVANCE OF, OR CONSTRUCTION WITHOUT PRIOR APPROVAL OF THE DESIGN ENGINEER, THE OWNER AND THE MUNICIPALITY.
- THE CONTRACTOR SHALL COMPLY WITH CONSTRUCTION INSPECTIONS REQUIREMENTS OF ALL AGENCIES, AND PHASE WORK ACCORDINGLY.
- THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO THE START OF CONSTRUCTION.
- FIELD ADJUSTMENT MUST BE REVIEWED BY A REPRESENTATIVE OF STANTEC ENGINEERING PRIOR TO INSTALLATION.
- PROTECT NEWLY GRADED WORK AREAS FROM TRAFFIC AND EROSION AND KEEP THEM FREE FROM TRASH AND DEBRIS UNTIL PHYSICAL COMPLETION OF WORK IN ACCORDANCE WITH THE PROJECT STORMWATER POLLUTION PREVENTION PLAN.
- CONTRACTORS OPERATIONS ON SITE WHICH SHALL INCLUDE BUT NOT BE LIMITED TO DUST CONTROL, MATERIAL HAULING, FIRE PROTECTION, EROSION CONTROL, ETC. SHALL BE CONDUCTED IN ACCORDANCE WITH TOWN OF BETHLEHEM REQUIREMENTS.
- LOCATE EXISTING UNDERGROUND UTILITIES IN AREAS OF WORK; IF UTILITIES ARE TO REMAIN IN PLACE, PROVIDE ADEQUATE MEANS OF SUPPORT AND PROTECTION DURING EARTHWORK OPERATIONS.
- ALL DRIVEWAY AND PARKING AREAS ARE TO BE ASPHALT PAVED SURFACES UNLESS OTHERWISE NOTED.
- ALL CONSTRUCTION AND MATERIALS SHALL BE IN ACCORDANCE WITH THE TOWN OF BETHLEHEM REGULATIONS AND CONSTRUCTION STANDARDS.
- THE STORMWATER BASINS, CONVEYANCE PIPING STRUCTURES WITHIN THE SITE SHALL BE PRIVATELY OWNED. MULTIPLE PATH USE PATH TO BE OWNED BY THE TOWN OF BETHLEHEM. THE OWNER SHALL BE RESPONSIBLE FOR ALL INSPECTIONS AND TESTING IN ACCORDANCE WITH THE TOWN OF BETHLEHEM.
- THE CONTRACTOR SHALL COORDINATE MAINTENANCE AND PROTECTION OF TRAFFIC WITH THE TOWN OF BETHLEHEM. ALL MAINTENANCE AND PROTECTION OF TRAFFIC SHALL BE IN ACCORDANCE WITH NYSDOT AND THE MANUAL OF UNIFORM TRAFFIC CONTROL DEVICES (MUTCD).
- ALL SANITARY SEWER AND STORM SEWERS FRAMES SHALL BE SET AT THE BINDER COURSE ELEVATION AND RAISED TO THE TOP COURSE ELEVATION AT THE TIME OF TOP COURSE PLACEMENT.
- WATER MAINS AND APPURTENANCES SHALL BE DISINFECTED IN ACCORDANCE WITH AWWA STANDARDS FOR DISINFECTION OF WATER MAINS, C-651-92, WITH THE EXCEPTION OF SECTION 5.1, TABLET METHOD. FINAL FLUSHING OF THE HEAVILY CHLORINATED WATER GENERATED FROM WATER DISINFECTION PROCESS SHALL BE NEUTRALIZED AND DISPOSED OF IN ACCORDANCE WITH AWWA STANDARDS FOR DISINFECTION OF WATER MAINS, C-651-99.
- WATER MAINS SHALL BE PRESSURE AND LEAKAGE TESTED IN ACCORDANCE WITH SECTION 4 OF THE AWWA C-600 LATEST EDITION.
- ALL DISTURBANCE LIMITS AND SETBACKS SHALL BE STAKED OR FLAGGED IN THE FIELD PRIOR TO BEGINNING GRADING AND CLEARING ACTIVITIES.
- CONTRACTOR TO VERIFY SIZE, TYPE AND DEPTH OF EXISTING WATER MAINS PRIOR TO CONNECTION AND VERIFY COMPATIBILITY OF TAPPING SLEEVE AND VALVES WITH THE DESIGN ENGINEER AND THE PRODUCT MANUFACTURER.
- STREET LIGHTS SHALL BE SPECIFIED, OWNED, OPERATED AND MAINTAINED BY THE HOME OWNERS ASSOCIATION.
- STREET NAME SIGNAGE SHALL BE DEVELOPMENT-THEMED AND OWNED AND MAINTAINED BY HOME OWNERS ASSOCIATION. TRAFFIC CONTROL SIGNAGE SHALL BE IN ACCORDANCE WITH M.U.T.C.D.
- ROOF LEADERS SHALL BE CONNECTED TO THE STORMWATER SYSTEM. FOOTING DRAINS TO BE DAYLIGHTED TO THE GREATEST EXTENT POSSIBLE.
- TREES, STUMPS AND ALL EXCESS EXCAVATED MATERIAL SHALL BE REMOVED FROM THE SITE AND LEGALLY DISPOSED OFF-SITE.
- ANY EXISTING ASPHALT CONCRETE PAVEMENT DAMAGED, OUTSIDE THE WORK LIMITS, SHALL BE REPLACED AS DIRECTED BY THE ENGINEER AT NO ADDITIONAL COST TO THE OWNER, AND/OR THE TOWN OF BETHLEHEM.

GENERAL DRAWING NOTES

- ALL TRAFFIC SIGNAGE FOR THE PROPOSED DEVELOPMENT SHALL CONFORM TO THE NEW YORK STATE MANUAL FOR UNIFORM TRAFFIC CONTROL DEVICES (MUTCD).
- SINGLE FAMILY RESIDENCE AND DRIVEWAY LOCATIONS SHOWN ON ALL SUBSEQUENT DRAWINGS ARE APPROXIMATE.
- ALL EROSION CONTROL MEASURES SHALL BE INSTALLED AND MAINTAINED IN ACCORDANCE WITH THE NEW YORK STANDARDS AND SPECIFICATIONS FOR EROSION AND SEDIMENT CONTROL AND THE PROJECT STORMWATER POLLUTION PREVENTION PLAN (SWPPP).
- ALL DISTURBED AREAS TO RECEIVE TOPSOIL, SEED, FERTILIZER AND MULCH TO ESTABLISH A PERMANENT STAND OF GRASS.
- ALL SANITARY SEWER MANHOLES LOCATED IN GRASSED AREAS SHALL HAVE RIM ELEVATIONS SET APPROXIMATELY 6" ABOVE FINISH GRADE TO PREVENT INFILTRATION.
- ALL HOMES WILL HAVE A SEWER CHECK VALVE INSTALLED WITHIN THE DWELLING.
- ALL STORM DRAIN LATERALS SHALL HAVE A CHECK VALVE INSTALLED IN THE CATCH BASIN THAT THE STORM DRAIN LATERAL CONNECTS TO.
- UPON ISSUANCE OF A BUILDING PERMIT, A TEMPORARY SIGN WITH 4" BLOCK LETTERS IS TO BE ERECTED AT THE SITE DISPLAYING THE HOUSE NUMBER. ONCE THE STRUCTURE IS COMPLETED, THE ADDRESS NUMBER IS TO BE DISPLAYED EITHER ON THE HOUSE OR MAILBOX WITH 4" LETTERS. IT WILL BE THE BUILDERS INSPECTOR'S RESPONSIBILITY TO INSURE THAT THE PROPER ADDRESS NUMBERS ARE DISPLAYED BEFORE A C.O. IS ISSUED.
- THE OWNER IS RESPONSIBLE FOR COORDINATING WITH NATIONAL GRID FOR ENERGY SERVICES.

LEGEND

PROPOSED		EXISTING	
<input type="radio"/>	PROPOSED STORM MANHOLE	<input type="radio"/>	EXISTING STORM MANHOLE
<input type="checkbox"/>	PROPOSED CATCH BASIN	<input type="checkbox"/>	EXISTING CATCH BASIN
FES	PROPOSED FLARED END SECTION		EXISTING HYDRANT
	PROPOSED SANITARY MANHOLE		EXISTING SANITARY MANHOLE
	PROPOSED GRINDER PUMP		EXISTING POLES
	PROPOSED HYDRANT		EXISTING WATER
	PROPOSED WATER LINE		EXISTING SANITARY
	PROPOSED SANITARY LINE		EXISTING STORM
	PROPOSED STORM LINE		EXISTING GRAVITY SEWER
	PROPOSED GAS LINE		EXISTING LOW PRESSURE
	PROPERTY LINE	STA	STATIONING
GFF=205.50	GARAGE FINISH FLOOR	OHW	OVERHEAD WIRES

INCHES
Town of Bethlehem, NY

ALBANY COUNTY DEPARTMENT OF HEALTH
DIVISION OF ENVIRONMENTAL HEALTH SERVICES
By direction of the Commissioner of Health, these
plans are hereby approved. See back sheet for
date and signature.

PLANNING BOARD
TOWN OF BETHLEHEM
ALBANY COUNTY, NEW YORK
President of the Board
These drawings are hereby approved.
See sheet(s) 3623
for date and signature.

DRAWING NUMBER: 123
JOB NO: 11-03
UNAUTHORIZED ALTERATION OR ADDITION TO THIS DOCUMENT IS A VIOLATION OF SECTION 7209 SUBDIVISION 2 OF THE NEW YORK STATE EDUCATION LAW

BREWER ENGINEERING ASSOCIATES, P.C.
CONSULTING ENGINEERS * PLANNERS
743 COLUMBIA TURNPIKE, EAST GREENBUSH, NEW YORK 12061
PHONE: 518.477.5253 FAX: 518.477.5233

VANDYKE SPINNEY
PHASE 2

TOWN OF BETHLEHEM COUNTY OF ALBANY
STATE OF NEW YORK