

FERNBANK

AVENUE

MAP OF PORTION OF HAMAGRAEL

SECTION #1






PROPERTY OF HOME CONSTRUCTION CORP.
SEPTIC TANK DETAILS & LAYOUT

ALBANY COUNTY DELMAR NEW YORK
JULY 16, 1952

NOTES


Design of Septic Tank is based upon (2) and (3) living units. Liquid capacity of Septic Tank shall be at least 500 gals. Commercial Tanks of an approved design may be substituted for the concrete tank as shown. Line from house sewer and line between Septic Tank and Distribution Box shall be bell and spigot type vitrified or concrete pipe, with water-tight joints. Disposal Field shall not be located within 10 feet of dwellings, lot lines, and large trees. Location of water mains subject to approval of local Water Commissioner. Soil tests were taken at present grade - Extensive grading would require new percolation tests. Grades of all tile lines should be strictly adhered to. It is suggested that for most efficient operation of Sewage Disposal system, any surface drainage be diverted from the disposal area.

KEY MAP
Scale: 1"=1000'



Notes
Grade of tile line to be 6"/100'
Tight joints required on all pipe between Distribution Box and Disposal Field.
Orangeburg perforated 4" pipe may be substituted for the 4" tile as shown and the Grade Board can be eliminated.

DISPOSAL TRENCH CONSTRUCTION
Scale: 1/8"=1'-0"



DISPOSAL FIELD DATA

LOT NUMBER AND STREET	PERCOLATION TEST	LENGTH OF TILE LINE	LOCATION OF FIELD
185 Winne	2:40	3:40	Layout 'B' on Albin Rd.
191	2:40	3:40	"
195	2:40	3:40	"
199	2:40	3:40	"
203	2:40	3:40	"
21	2:40	3:40	Not for approval - to be filled
55	2:40	3:40	Layout 'C' near lot #35
59	2:40	3:40	"
63	2:40	3:40	Parallel to and near lot #20
20	2:40	3:40	Layout 'B' near lot #63
10	2:40	3:40	"
14	2:40	3:40	"
203 Winne	"	"	Layout 'B' - Lot filled - tile not to be constructed before Feb. 10, 1953
8 Wisconsin	2:40	3:40	Layout 'B' facing Wisconsin Ave.
14	2:40	3:40	"
9	2:40	3:40	"
18	2:40	3:40	"

Survey and Map by:
Edward W. Boudelle
Civil Engineer & S.
Delmar, N.Y.
N.Y. State License

NOTE #18 Denotes Lot number and House number
#1 - 1 Minute test - sand to 7.5' no ground water
#2 - 3 - sand with traces of clay ground water at 4'-10"
#3 - 3 - sand - ground water at 6'-6"
#4 - 3 - sand - ground water at 4'-8"
#5 - 5 -

Scale: 1"=50'

This line to measure 5' after reduction